



Fucoli Somepal
FUNDIÇÃO DE FERRO, S.A.

DESDE
SINCE 1946

PRODUCT DECLARATION OF CONFORMITY

The manufacturer: FUCOLI-SOMEPAL - Fundação de Ferro, S.A.

Head office:

Estrada de Coselhas
3011-906 Coimbra, Portugal

Branch office:

Rua de Aveiro, 50
3050-903 Pampilhosa, Portugal

hereby declares that product: All movable flanged tee

with construction: according to EN 545:2006

with connections: Flanged with drilling according to EN 1092-2

with ranges: DN 40 to DN 1000 and pressures PN 10 to PN 25

with materials and standards: Ductile iron (EN-GJS-500-7)

Epoxy paint potable RESICOAT 9000 R4
BLUE applied electrostatically with
thickness $\geq 250 \mu\text{m}$

EN 1563

DIN 30677 and
according to
the requirements
of GSK (RAL-GZ662)

**are according to our technical
datasheet:** 10.1200

Coimbra, 13 of May of 2016

Elsa Silva

Management System Director



SEDE / HEAD OFFICE:
Apartado 467 - Coselhas
3001-906 Coimbra - Portugal
Tel. +351 239 490 100 - Fax +351 239 490 198
Gps 40° 13' 16.64" N - 8° 25' 40.18" W
sede@fucoli-somepal.pt

FILIAL / BRANCH OFFICE:
Apartado 4 - Rua de Aveiro, 50
3050-903 Pampilhosa - Portugal
Tel. +351 239 490 100 - Fax +351 231 949 292
Gps 40° 21' 02.97" N - 8° 26' 18.32" W
filial@fucoli-somepal.pt

Contribuinte n.º / Tax number PT 504346701 - Capital Social / Capital: € 7.095.000
Reg. na C.R.C. Coimbra, sob o n.º 7473 / Registered in the commercial register of Coimbra with the number 7473
C.A.E. (Portuguese classification of economic activities) 24510

www.fucoli-somepal.pt



Tampa Elco Dob D400
Manhole cover with flange D400
Tampa Luso B125
Manhole cover Luso B125
Tampa Reb. NR1, NR2, NR3 D400
Recessed Manhole cover NR1, NR2, NR3 B125
Tampa Estanque D400
Manhole cover Estanque D400
Marco de Incêndio Somepal
Fire Hydrant Classic
Marco de Incêndio Ignis Inox
Fire Hydrant Ignis Inox
Hidrate Enterrado
Underground Fire Hydrant