

PRODUCT DECLARATION OF CONFORMITY

FUCOLI-SOMEPAL - Fundição de Ferro, S.A. The manufacturer:

> Head office: Branch office:

Estrada de Coselhas Rua de Aveiro. 50

3011-906 Coimbra, Portugal 3050-903 Pampilhosa, Portugal

Flanged gate valve SERIES 3000 hereby declares that product:

> with connections: Flanged with drilling according to EN 1092-2 and face-to-face dimension

> > according to EN 558 (Series 15)

with ranges: DN 40 to DN 600 and pressure of PN 25

with materials and standards: Ductile iron (EN-GJS-500-7) EN 1563

> EPDM elastomer with CE marking EN 681-1

EN 12164 **Brass**

EN 10088-1 Stainless steel AISI 420

Stainless steel A2 EN 10088-1

DIN 30677 and Epoxy paint potable RESICOAT 9000 R4

BLUE applied electrostatically with

thickness ≥ 250 µm

GSK-ID: 1247

approved epoxy coating (RAL-GZ662)

are according to our technical

datasheets:

01.202

Coimbra, 03 of May of 2016



Management System Director



SEDE / HEAD OFFICE: Apartado 467 - Coselhas 3001-906 Coimbra - Portugal Tel. +351 239 490 100 - Fax +351 239 490 198 Gps 40° 13′ 16.64″ N - 8° 25′ 40.18″ W sede@fucoli-somepal.pt

FILIAL / BRANCH OFFICE:

Apartado 4 - Rua de Aveiro, 50 3050-903 Pampilhosa - Portugal Tel. +351 239 490 100 - Fax +351 231 949 292 Gps 40° 21' 02.97" N - 8° 26' 18.32" W filial@fucoli-somepal.pt





