

AENOR Product Certificate

Isolating valves for water supply



B18/000002

AENOR, Spanish Association for Standardization and Certification, certifies that the organization

FUCOLI-SOMEPAL FUNDIÇÃO DE FERRO, S.A.

registered office CL ESTRADA DE COSELHAS 3001-906 COIMBRA (Portugal)

supplies Isolating valves for water supply

in compliance with UNE-EN 1074-1:2001 (EN 1074-1:2000)
UNE-EN 1074-1:2001 ERRATUM:2008
UNE-EN 1074-2/A1:2004 (EN 1074-2:2000/A1:2004)
UNE-EN 1074-2:2001 (EN 1074-2:2000)

References Specified in Annex to the Certificate

Production site RUA DE AVEIRO, 50 3050-903 PAMPILHOSA (Portugal)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP B18 01

First issued on 2009-02-16
Last issued 2014-02-16
Validity date 2019-02-16

AENOR

Asociación Española de
Normalización y Certificación

Avelino BRITO
Chief Executive Officer

AENOR

Asociación Española de
Normalización y Certificación

Génova, 6. 28004 Madrid. España
Tel. 902 102 201 - www.aenor.es

AENOR Product Certificate

Isolating valves for water supply

B18/000002

Annex to Certificate

Trade Mark	Type of valve	Type of flow	Type of seal	Service temperatures
FUCOLI-SOMEPAL	GATE	COMPLETE	ELASTIC	0 / 70 °C

Model	Type of ends	PN	DN
3000 PN 10/16	FLANGE	16	40, 50, 60, 65, 80, 100, 125, 150, 200, 250, 300, 350, 400, 450, 500, 600
3000 PN 10/16	PVC SOCKET CONNECTION	16	40, 50, 65, 80, 100, 125, 150, 200, 250, 300, 400, 500
3000 PN 10/16	PE SPIGOT ENDS	16	50, 65, 80, 100, 125, 150, 200, 250, 300, 400
3000 PN 25	FLANGE	25	40, 50, 60, 65, 80, 100, 125, 150, 200, 250, 300

AENOR Asociación Española de
Normalización y Certificación

First issued on 2009-02-16
Last issued 2014-02-16
Validity date 2019-02-16