

PRODUCT DECLARATION OF CONFORMITY

The manufacturer: FUCOLI-SOMEPAL - Fundição de Ferro, S.A.

Head office: Branch office:

Estrada de Coselhas Rua de Aveiro, 50

3011-906 Coimbra, Portugal 3050-903 Pampilhosa, Portugal

hereby declares that product: Flanged gate valve SERIES 3000

with connections: Flanged with drilling according to EN 1092-2, face-to-face dimension according

to EN 558 (Series 15) and ISO top flange according to ISO 5210

with ranges: DN 40 to DN 600 and pressures of PN 10 to PN 16

with materials and standards: Ductile iron (EN-GJS-500-7) EN 1563

EPDM elastomer with CE marking EN 681-1

Brass EN 12164

Stainless steel AISI 420 EN 10088-1

Stainless steel A2 EN 10088-1

Epoxy paint potable RESICOAT 9000 R4

BLUE applied electrostatically with

thickness ≥ 250 μm

DIN 30677 and GSK-ID: 1247

approved epoxy

coating (RAL-GZ662)

are according to our technical

datasheets:

01.203

Coimbra, 03 of May of 2016



Management System Director



SEDE / HEAD OFFICE:

Apartado 467 - Coselhas
3001-996 Colmbra - Portugal
Tel. +351 239 490 100 - Fax +351 239 490 198
Aps 40- 13' 16.64" N - 8- 25' 40.18" W
sede@fucoli-somepal.pt

FILIAL / BRANCH OFFICE:

Apartado 4 - Rua de Aveiro, 50 3050-903 Pampilhosa - Portugal Tel. +351 239 490 100 - Fax +351 231 949 292 6ps 40° 21' 02.97" N - 8° 26' 18.32" W fillal@fucoll-somepal,pt



