

DECLARAÇÃO DE CONFORMIDADE DE PRODUTO

O fabricante: FUCOLI-SOMEPAL - Fundição de Ferro, S.A.

Sede:

Estrada de Coselhas
3011-906 Coimbra, Portugal

Filial:

Rua de Aveiro, 50
3050-903 Pampilhosa, Portugal

**declara sob sua
responsabilidade que:**

Junta flange/multimateriais com garras sistema GFIX

e as tolerâncias: de 39/52 a 390/430 para as pressões de serviço PN 6/10/16

com os materiais e normas:

Ferro fundido dúctil (EN-GJS-500-7)	EN 1563
Elastómero EPDM com marcação CE	EN 681-1
POM (polióxido de metileno)	-
Aço temperado cq 15	DIN 1654
Aço inox A2 (X5 CrNi 18-10)	EN 10088-1
Aço inox A4 (X5 CrNiMo 17-12-2)	EN 10088-1
Tinta epóxica potável RAL 5005 aplicada electrostaticamente com espessura $\geq 250 \mu\text{m}$.	DIN 30677 e aprovado segundo o GSK-ID: 1247 (RAL-GZ662)

**está de acordo com a ficha
técnica:**

08.401

Coimbra, 22 de Novembro de 2016

Elsa Silva

Diretora do Sistema de Gestão



SEDE / HEAD OFFICE:
Apartado 467 - Coselhas
3001-906 Coimbra - Portugal
Tel. +351 239 490 100 - Fax +351 239 490 198
Gps 40° 13' 16.64" N - 8° 25' 40.18" W
sede@fucoli-somepal.pt

FILIAL / BRANCH OFFICE:
Apartado 4 - Rua de Aveiro, 50
3050-903 Pampilhosa - Portugal
Tel. +351 239 490 100 - Fax +351 231 949 292
Gps 40° 21' 02.97" N - 8° 26' 18.32" W
filial@fucoli-somepal.pt

Contribuinte n.º / Tax number PT 504346701 - Capital Social / Capital: € 7.095.000
Reg. na C.R.C. Coimbra, sob o n.º 7473 / Registered in the commercial register of Coimbra with the number 7473
CAE (Portuguese classification of economic activities) 24510

www.fucoli-somepal.pt



Tampa Eixo Dob D400
Manhole cover with Ring D400
Tampa Luso B125
Manhole cover Luso B125
Tampa NR1, NR2, NR3 D400
Manhole cover NR1, NR2, NR3 D400
Tampa Reb. NR1, NR2, NR3 B125
Recessed Manhole cover NR1, NR2, NR3 B125
Tampa Estanque D400
Manhole cover Estanque D400
Marco de Incêndio Somepal
Fire Hydrant Somepal
Marco de Incêndio Classic
Fire Hydrant Classic
Marco de Incêndio Ignis Inox
Fire Hydrant Ignis Inox
Hidrate Enterrado
Underground Fire Hydrant