



Fucoli Somepal
FUNDIÇÃO DE FERRO, S.A.

DESDE
SINCE 1946

PRODUCT DECLARATION OF CONFORMITY

The manufacturer: FUCOLI-SOMEPAL - Fundação de Ferro, S.A.

Head office:

Estrada de Coselhas
3011-906 Coimbra, Portugal

Branch office:

Rua de Aveiro, 50
3050-903 Pampilhosa, Portugal

hereby declares that product: Flanged gate valve SERIES 3000

with connections: Flanged with drilling according to EN 1092-2 and face-to-face dimension according to EN 558 (Series 14)

with ranges: DN 40 to DN 500 and pressures of PN 10 to PN 16

with materials and standards:	Ductile iron (EN-GJS-500-7)	EN 1563
	EPDM elastomer with CE marking	EN 681-1
	Brass	EN 12164
	Stainless steel AISI 420	EN 10088-1
	Stainless steel A2	EN 10088-1
	Epoxy paint potable RESICOAT 9000 R4 BLUE applied electrostatically with thickness $\geq 250 \mu\text{m}$	DIN 30677 and GSK-ID: 1247 approved epoxy coating (RAL-GZ662)

**are according to our technical
datasheets:** **01.101**

Coimbra, 03 of May of 2016

Elsa Silva

Management System Director



SEDE / HEAD OFFICE:
Apartado 467 - Coselhas
3001-906 Coimbra - Portugal
Tel. +351 239 490 100 - Fax +351 239 490 198
Gps 40° 13' 16.64" N - 8° 25' 40.18" W
sede@fucoli-somepal.pt

FILIAL / BRANCH OFFICE:
Apartado 4 - Rua de Aveiro, 50
3050-903 Pampilhosa - Portugal
Tel. +351 239 490 100 - Fax +351 231 949 292
Gps 40° 21' 02.97" N - 8° 26' 18.32" W
filial@fucoli-somepal.pt

Contribuinte n.º / Tax number PT 504348701 • Capital Social / Capital: € 7.095.000
Reg. na C.R.C. Coimbra, sob o n.º 7473 / Registered in the commercial register of Coimbra with the number 7473
C.A.E. (Portuguese classification of economic activities) 24510

www.fucoli-somepal.pt



Tampa Eixo Dob D400
Manhole cover with Ring D400
Tampa Luso B125
Manhole cover Luso B125
Tampa Reb. NR1, NR2, NR3 D400
Recessed Manhole cover NR1, NR2, NR3 B125
Tampa Estanque D400
Manhole cover Estanque D400
Marco de Incêndio Somepal
Fire Hydrant Classic
Marco de Incêndio Classic
Fire Hydrant Ignis Inox
Hidrante Enterrado
Underground Fire Hydrant